

Certificate of Compliance

Certificate: 1216481

Master Contract: 204767

Project: 1216481

Date Issued: November 13, 2001

Issued to: **Camille Bauer AG**
Aarauerstrasse 7
CH-5610 Wohlen
SWITZERLAND

Attention: Mr. Achim Atland

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Issued by:

Enzo De Simone, B.A.Sc.

Authorized by:

Nick Alfano
Operations Manager

PRODUCTS

CLASS 3631 04 - ELECTRICAL MEASUREMENT AND TEST EQUIPMENT

CLASS 3631 84 - ELECTRICAL EQUIPMENT FOR MEASUREMENT USE - CERTIFIED TO U.S. STANDARDS

PART A: AC Voltage Transducer, Model SINEAX U543, fixed equipment, rated 600Vac, 50/60Hz, 2VA (max), Equipment Class II, Pollution Degree 2, Installation Category III.

PART B: AC Current Transducer, Model SINEAX I542, fixed equipment, rated 7.5A, 2.5VA (max), Equipment Class II, Pollution Degree 2, Installation Category III.

NOTE: The Part A and Part B models above have the alternate model designations DVT-XXX and DCT-XXX respectively for Ohio Semitronics, Inc., where 'XXX' may represent 3 digits that indicate the input/output measuring values. In addition, the model number may be followed by the letter 'A' to denote that the unit is powered by the measuring input.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 1010.1-92

- Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements (Includes Amendment 1)

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognised to perform certification to U.S. Standards.



CSA INTERNATIONAL

Certificate: 1216481

Master Contract: 204767

Project: 1216481

Date: November 13, 2001

-
- | | | |
|------------------------------|---|---|
| CAN/CSA-C22.2 No. 1010.1B-97 | - | Amendment 2 to CAN/CSA-C22.2 No. 1010.1-92, "Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements" |
| UL Std No. 3111.1 | - | Equipment for Measurement Use; Part 1: General Requirements |



Supplement to Certificate of Compliance

Certificate: 1216481

Master Contract: 204767

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
1216481	November 13, 2001	Original Certification.